



GALLON CAPACITY	*OUTSIDE DIMENSIONS			INLET TEE HGT.	OUTLET TEE HGT.
	LENGTH	WIDTH	HEIGHT		
3000	15'-7"	9'-7"	8'-6.5"	*VARIES BASED ON TANK SIZE	
1500	11'-0"	6'-0"	4'-7"		
1000	8'-6"	5'-3"	4'-6"		
750	7'-0"	4'-8"	4'-6"		

\*DIMENSIONS OF PREFAB CONCRETE TANKS MAY VARY BASED ON MANUFACTURER, HOWEVER THE GALLON CAPACITY MUST BE EQUIVALENT TO THE TANK SIZE SPECIFIED FOR INSTALLATION.

BAFFLE STANDS 60" IN HEIGHT AND IS 2 1/2" IN THICKNESS REINFORCED W/ 6-6-10 WIRE MESH  
PIPE DIAMETER MAY VARY STANDARD 3"-5"  
PVC PIPE REQ'D ON WALL WITH ELBOW TURNED DOWN MAX. 2' OFF TANK BOTTOM  
\* BAFFLE WALL OPTIONAL ON SINGLE TANK INSTALLATIONS.

BAFFLE WALL\*  
N.T.S.

FULTON COUNTY STANDARD DETAIL 702  
SINGLE TANK

DATE	REVISIONS	DATE	REVISIONS

DGS/DRN/CHKD: JM  
APPROVED: BEW  
DATE: 12-2-05



FULTON COUNTY PUBLIC WORKS  
141 PRYOR ST. ATLANTA, GA. 30303  
404-730-7400 FAX: 404-224-0498

DRAWING NO.  
702